

Cathodic Protection of Aboveground Petroleum Storage Tanks

API RECOMMENDED PRACTICE 651
SECOND EDITION, NOVEMBER 1997



Cathodic Protection of Aboveground Petroleum Storage Tanks

Manufacturing, Distribution, and Marketing Department

API RECOMMENDED PRACTICE 651
SECOND EDITION, NOVEMBER 1997



SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Authoring Department [telephone (202) 682-8000]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the director of the Authoring Department (shown on the title page of this document), American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.

Copyright © 1997 American Petroleum Institute

FOREWORD

This recommended practice describes the corrosion problems characteristic in above-ground steel storage tanks and associated piping systems and provides a general description of the two methods currently used to provide cathodic protection against corrosion.

Persons planning to construct an aboveground storage facility, replace existing above-ground storage tanks and associated piping systems, or cathodically protect existing above-ground storage tanks and associated piping should refer to applicable local, state, and federal fire, safety, and environmental regulations as well as the most recent edition of the following publications:

- a. API Standard 650.
- b. API Recommended Practice 1615.
- c. API Recommended Practice 1621.
- d. API Recommended Practice 652.
- e. API Standard 653.
- f. API Specification 12B.
- g. API Specification 12D.
- h. API Specification 12F.
- i. NACE RP0169.
- j. NACE RP0193.
- k. NACE RP0285.
- l. NFPA 30.
- m. NFPA 70.
- n. PEI RP100.

Legislation and regulations related to the design, installation, operation, and maintenance of cathodic protection systems for aboveground petroleum storage systems are under development at the federal, state, and municipal levels. Therefore, the appropriate government authority having jurisdiction should be consulted for regulations that apply to the area of installation prior to taking any action suggested in this recommended practice.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to the director of Manufacturing, Distribution and Marketing, American Petroleum Institute, 1220 L Street, N.W., Washington D. C. 20005.

CONTENTS

	Page
1 SCOPE.....	1
2 REFERENCED PUBLICATIONS.....	1
3 DEFINITIONS.....	2
4 CORROSION OF ABOVEGROUND STEEL STORAGE TANKS	4
4.1 Introduction	4
4.2 Corrosion Mechanisms	4
4.2.1 Stray Current Corrosion.....	4
4.2.2 Galvanic Corrosion	5
4.2.3 Internal Corrosion	5
5 DETERMINATION OF NEED FOR CATHODIC PROTECTION	6
5.1 Introduction	6
5.1.1 New Aboveground Storage Tanks	6
5.1.2 Existing Aboveground Storage Tanks	6
5.1.3 Internal Cathodic Protection	6
5.1.4. Limitations of External Cathodic Protection.....	6
5.2 Tank History.....	6
5.3 Foundations and Soil Conditions.....	7
5.3.1 Introduction	7
5.3.2 Continuous Concrete Cushion.....	7
5.3.3 Continuous Asphalt Cushion	8
5.3.4 Native Soil Cushion	8
5.3.5 Clean-Sand or Oiled-Sand Cushion	8
5.3.6 Contaminated Soil Cushion.....	8
5.3.7 Crushed-Limestone or Clam-Shell Cushion	9
5.4 Other Factors Affecting Cathodic Protection	9
5.4.1 Contents of Tank	9
5.4.2 Bottom Replacement	9
5.4.3 Secondary Containment.....	9
5.4.4 Thick-Film Internal Linings	9
6 METHODS OF CATHODIC PROTECTION FOR CORROSION CONTROL....	10
6.1 Introduction	10
6.2 Galvanic Systems.....	10
6.2.1 General.....	10
6.2.2 Advantages of Galvanic Systems	11
6.2.3 Disadvantages of Galvanic Systems	11
6.3 Impressed Current Systems	11
6.3.1 General.....	11
6.3.2 Advantages of Impressed Current Systems.....	11
6.3.3 Disadvantages of Impressed Current Systems	11
6.3.4 Cathodic Protection Rectifiers.....	11
6.3.5 Impressed Current Anodes.....	12
7 DESIGN OF CATHODIC PROTECTION SYSTEMS.....	12
7.1 Introduction	12

7.2	Influence of Replacement Bottoms, Linings, and Secondary Containment on Design	12
7.2.1	Barriers to Cathodic Protection	12
7.2.2	Tank Bottom Replacement	12
7.2.3	Considerations When Secondary Containment is Used in a Diked Area	12
7.2.4	Replacement or Repair of Steel Tank Bottoms	13
7.2.5	Effects of Impermeable Membrane Secondary Containment Systems	15
7.3	External Cathodic Protection	15
7.3.1	Introduction	15
7.3.2	Design Considerations	15
7.3.3	Information Useful for Design	15
7.3.4	Considerations That Influence Selection of the Type of Cathodic Protection System	16
7.3.5	Types of Cathodic Protection Systems	16
7.3.6	Electrical Isolation	18
7.4	Internal Cathodic Protection	18
8	CRITERIA FOR CATHODIC PROTECTION	18
8.1	Introduction	18
8.2	Protection Criteria	18
8.3	Measurement Techniques	19
8.4	Alternative Reference Electrodes	20
9	INSTALLATION OF CATHODIC PROTECTION SYSTEMS	20
9.1	Introduction	20
9.2	Galvanic Anode Systems	20
9.3	Impressed Current Systems	20
9.3.1	Introduction	20
9.3.2	Shallow Groundbed Installation	21
9.3.3	Deep Groundbed Installation	21
9.3.4	Rectified Installation	21
9.3.5	Cable Installation	22
9.4	Corrosion Control Test Stations, Connections, and Bonds	22
10	INTERFERENCE CURRENTS	23
10.1	Introduction	23
10.2	Sources of Interference Currents	24
10.2.1	Constant Current	24
10.2.2	Fluctuating Current	24
10.3	Detection of Interference Currents	24
10.4	Control of Interference Currents	24
11	OPERATION AND MAINTENANCE OF CATHODIC PROTECTION SYSTEMS	24
11.1	Introduction	24
11.2	Safety	25
11.3	Cathodic Protection Surveys	25
11.4	Cathodic Protection Records	26

Figures

1	Electrochemical Corrosion Cell	4
2	Oxygen Concentration Cell Caused by Rocks or Clay in Tank Cushion	4
3	Example of Stray Current Corrosion of an Unprotected Tank Bottom	5
4	Galvanic Corrosion	5
5	Galvanic Cathodic Protection With Sacrificial Anodes	11
6	Impressed Current Cathodic Protection	11
7	Impervious Membrane Beneath Storage Tank	13
8	New Steel Bottom on Top of Old Bottom	14
9	Current Requirement Test Setup	17
10	Potential Measurement Schematic	19
11	Typical Galvanic Anode Installation.	20
12	Typical Shallow Groundbed Installation	21
13	Commonly Installed Deep Groundbed	22
14	Permanently Installed Reference Electrode and Test Station.	23
15	Perforated Pipe Installed for Reference Electrode	24

Tables

1	General Classification of Resistivity.	7
2	Guideline for Reviewing Soil Analysis Data	8
3	Partial Galvanic Series	10
4	Commonly Used Reference Electrodes	20

Cathodic Protection of Aboveground Petroleum Storage Tanks

1 Scope

1.1 The purpose of this recommended practice is to present procedures and practices for achieving effective corrosion control on aboveground storage tank bottoms through the use of cathodic protection. It contains provisions for the application of cathodic protection to existing and new storage tanks. Corrosion control methods based on chemical control of the environment or the use of protective coatings are not covered in detail.

1.2 The intent of this recommended practice is to provide information and guidance specific to aboveground steel storage tanks in hydrocarbon service. Certain practices recommended herein may also be applicable to tanks in other services. It is intended to serve only as a guide to persons interested in cathodic protection. Specific cathodic protection designs are not provided. Such designs should be developed by a person thoroughly familiar with cathodic protection practices.

1.3 This recommended practice does not designate specific practices for every situation because the varied conditions in which tank bottoms are installed preclude standardization of cathodic protection practices.

2 Referenced Publications

API

Spec 12B	<i>Specification for Bolted Tanks for Storage of Production Liquids</i>
Spec 12D	<i>Specification for Field Welded Tanks for Storage of Production Liquids</i>
Spec 12F	<i>Specification for Shop Welded Tanks for Storage of Production Liquids</i>
RP 500	<i>Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities (ANSI/API Std 500)</i>
RP 575	<i>Inspection of Atmospheric and Low-Pressure Storage Tanks</i>
Std 620	<i>Design and Construction of Large, Welded, Low-Pressure Storage Tanks</i>
Std 650	<i>Welded Steel Tanks for Oil Storage</i>
RP 652	<i>Lining of Aboveground Petroleum Storage Tank Bottoms</i>
Std 653	<i>Tank Inspection, Repair, Alteration, and Reconstruction</i>
RP 1615	<i>Installation of Underground Petroleum Product Storage Systems</i>
RP 1621	<i>Bulk Liquid Stock Control at Retail Outlets</i>

RP 1632	<i>Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems</i>
RP 2003	<i>Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents</i>
ASTM ¹	
G 57	<i>Method for Field Measurement of Soil Resistivity Using the Wenner Four Electrode Method</i>
NACE Int ¹²	
51011	<i>Control of Pipeline Corrosion</i>
Pub 10AI90	<i>Measurement Techniques Related to Criteria for Cathodic Protection of Underground or Submerged Steel Piping Systems</i>
RP0169	<i>Control of External Corrosion on Underground or Submerged Metallic Piping Systems</i>
RP0177	<i>Mitigation of Alternating Current and Lightning Effects on Metallic Structures and Corrosion Control Systems</i>
RP0285	<i>Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems</i>
RP0388	<i>Impressed Current Cathodic Protection of Internal Submerged Surfaces of Steel Water Storage Tanks</i>
RP0572	<i>Design, Installation, Operation, and Maintenance of Impressed Current Deep Groundbeds</i>
RP0575	<i>Internal Cathodic Protection Systems in Oil Treating Vessels</i>
RP0193	<i>External Cathodic Protection of On-Grade Metallic Storage Tank Bottoms</i>
TPC Pub 11	<i>A Guide to the Organization of Underground Corrosion Control Coordinating Committees</i>
NFPA ³	
30	<i>Flammable and Combustible Liquids Code</i>
70	<i>National Electrical Code</i>
PEI ⁴	
RP100	<i>Recommended Practices for the Installation of Underground Liquid Storage Systems</i>

¹American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

²NACE International, P.O. Box 218340, Houston, Texas 77218.

³National Fire Protection Association, Batterymarch Park, Quincy, Massachusetts 02269-9990.

⁴Petroleum Equipment Institute, P.O. Box 2380, Tulsa, Oklahoma 74101.

3 Definitions

Definitions in this section reflect the common usage among practicing corrosion control personnel. In many cases, in the interests of brevity and practicality, the strict scientific definitions have been abbreviated or paraphrased.

3.1 aboveground storage tank: A stationary container, of greater than 500 barrel capacity usually cylindrical in shape, consisting of a metallic roof, shell, bottom, and support structure where more than 90 percent of the tank volume is above surface grade.

3.2 anode: The electrode of an electrochemical cell at which oxidation (corrosion) occurs. Antonym: cathode.

3.3 backfill: Material placed in a hole to fill the space around anodes, vent pipe, and buried components of a cathodic protection system. Anodes can be prepackaged with backfill material for ease of installation.

3.4 breakout piping: All piping associated with the transfer of products in and out of storage tanks.

3.5 cathode: The electrode of an electrochemical cell at which a reduction reaction occurs. Antonym: anode.

3.6 cathodic protection: A technique to reduce corrosion of a metal surface by making the entire surface the cathode of an electrochemical cell.

3.7 coke breeze: A carbonaceous backfill material.

3.8 continuity bond: A metallic connection that provides electrical continuity.

3.9 corrosion: The deterioration of a material, usually a metal, that results from a reaction with its environment.

3.10 current density: The current per unit area flowing to or from a metallic surface.

3.11 current requirement test: Creates direct current flow from a temporary ground bed to the structure to be protected to determine the amount of current necessary to protect that structure.

3.12 deep groundbed: One or more anodes installed vertically at a nominal depth of 15 m (50 ft) or more below the earth's surface in a single drilled hole for the purpose of supplying cathodic protection.

3.13 differential aeration cell: An electrochemical cell the electromotive force of which is due to a difference in air (oxygen) concentration at one electrode as compared with that at another electrode of the same material.

3.14 electrical isolation: The condition of being electrically separated from other metallic structures or the environment.

3.15 electrical isolation cell: An electrical circuit where electrical current flows from certain areas of a metal to other areas through a solution capable of conducting electricity (electrolyte).

3.16 electrochemical cell: An electrochemical system consisting of an anode and a cathode immersed in an electrolyte so as to create an electrical circuit. The anode and cathode may be separate metals or dissimilar areas on the same metal. The cell includes the external circuit which permits the flow of electrons from the anode toward the cathode.

3.17 electrode potential: The potential of an electrode as measured against a reference electrode. (The electrode potential does not include any resistance losses in potential in either the electrolyte or the external circuit. It represents the reversible work required to move a unit charge from the electrode surface through the electrolyte to the reference electrode.)

3.18 electrolyte: A chemical substance containing ions that migrate in an electric field. For the purposes of this recommended practice, electrolyte refers to the soil or liquid adjacent to and in contact with the bottom of an aboveground petroleum storage tank, including the moisture and other chemicals contained therein.

3.19 environmental cracking: The brittle fracture of a normally ductile material in which the corrosive effect of the environment is a causative factor.

3.20 external circuit: Consists of the wires, connectors, measuring devices, current sources, etc., that are used to bring about or measure the desired electrical conditions within an electrochemical cell. It is this portion of the cell through which electrons travel.

3.21 foreign structure: Any metallic structure that is not intended as a part of a system under cathodic protection.

3.22 galvanic anode: A metal that, because of its relative position in the galvanic series, provides sacrificial protection to another metal that is more noble, when electrically coupled in an electrolyte. These anodes are the source of current in one type of cathodic protection.

3.23 galvanic series: A list of metals and alloys arranged according to their relative potentials in a given environment.

3.24 groundbed: Consists of one or more anodes installed below the earth's surface for the purpose of supplying cathodic protection.

3.25 holiday: A discontinuity in a protective coating that exposes unprotected surface to the environment.

3.26 impressed current: An electric current supplied by a device employing a power source that is external to the elec-

trode system. (An example is direct current for cathodic protection.)

3.27 insulating coating system: All components of the protective coating, the sum of which provides effective electrical insulation of the coated structure.

3.28 interference bond: A metallic connection designed to control electrical current interchange between metallic systems.

3.29 IR drop: The voltage generated across a resistance by an electrical current in accordance with Ohm's Law: $E = I \times R$. For the purpose of this recommended practice, the most significant IR drop is the portion of a structure-to-soil potential caused by a high resistance electrolyte between the structure and the reference electrode or by current flow from the anodes to the tank bottom.

3.30 isolation: Electrical isolation.

3.31 liner: A system or device, such as a membrane, installed beneath a storage tank, in or on the tank dike, to contain any accidentally escaped product.

3.32 membrane: A thin, continuous sheet of nonconductive synthetic material used to contain and/or separate two different environments.

3.33 oxidation: The loss of electrons by a constituent of a chemical reaction.

3.34 polarization: The change from the open-circuit potential of an electrode resulting from the passage of current. (In this recommended practice, it is considered to be the change of potential of a metal surface resulting from the passage of current directly to or from an electrode.)

3.35 rectifier: A device for converting alternating current to direct current. Usually includes a step-down AC transformer, a silicon or selenium stack (rectifying elements), meters, and other accessories when used for cathodic protection purposes.

3.36 reduction: The gain of electrons by a constituent of a chemical reaction.

3.37 reference electrode: An electrode whose open-circuit potential is constant under similar conditions of measurement.

3.38 resistor: A device used within an electrical circuit to control current flow.

3.39 sacrificial anode: Another name commonly used for a galvanic anode.

3.40 sacrificial protection: The reduction or prevention of corrosion of a metal in an electrolyte by galvanically coupling it to a more anodic metal.

3.41 secondary containment: A device or system used to control the accidental escape of a stored product so it may be properly recovered or removed from the environment. For the purpose of this recommended practice, secondary containment refers to an impermeable membrane.

3.42 shallow anode groundbed: A group of cathodic protection anodes installed individually, spaced uniformly, and typically buried less than 20 feet below grade.

3.43 shunt: A conductor of a known electrical resistance through which current flow may be determined by measurement of the voltage across the conductor.

3.44 stationary: Something that is permanently installed on the ground or on a foundation.

3.45 stray current: Current flowing through paths other than the intended circuit.

3.46 stray current corrosion: Corrosion resulting from direct current flow through paths other than the intended circuit.

3.47 stress corrosion cracking: The fracture of a metal by the combined action of corrosion and tensile stress. The fracture occurs under a tensile stress that may be well below the tensile strength or even the yield strength of the material.

3.48 structure-to-electrolyte voltage (also structure-to-soil potential or pipe-to-soil potential): The voltage difference between a metallic structure and the electrolyte which is measured with a reference electrode in contact with the electrolyte.

3.49 structure-to-structure voltage (also structure-to-structure potential): The difference in voltage between metallic structures in a common electrolyte.

3.50 tank cushion: The material immediately adjacent to the exterior steel bottom of an aboveground storage tank.

3.51 tank pad: Another name for a tank cushion.

3.52 test lead: An electrically conductive cable attached to a structure and leading to a convenient location. It is used for the measurement of structure-to-electrolyte potentials and other measurements.

3.53 test station: A small enclosed box-like housing and the usual termination point of one or more test leads.

3.54 voltage: An electromotive force, or a difference in electrode potentials expressed in volts. Also known as a *potential*.

3.55 water bottom: A water layer in the bottom of a tank caused by separation of water and product due to differences in solubility and specific gravity

4 Corrosion of Aboveground Steel Storage Tanks

4.1 INTRODUCTION

4.1.1 Corrosion may be defined as the deterioration of a metal that results from a reaction with its environment. Corrosion of steel structures is an electrochemical process. For the corrosion process to occur, areas with different electrical potentials must exist on the metal surface. These areas must be electrically connected and in contact with an electrolyte.

There are four components in each corrosion cell: an anode, a cathode, a metallic path connecting the anode and cathode, and an electrolyte (see Figure 1). The role of each component in the corrosion process is as follows:

- At the anode, the base metal goes into solution (corrodes) by releasing electrons and forming positive metal ions. For steel, the anodic reaction is $\text{Fe} \rightarrow \text{Fe}^{+2} + 2\text{e}^-$.
- At the cathode, chemical reactions take place using electrons released at the anode. No corrosion takes place at the cathode. One common cathodic reaction is $\text{O}_2 + 2\text{H}_2\text{O} + 4\text{e}^- \rightarrow 4\text{OH}^-$.
- The metallic path provides a way for electrons released at the anode to flow to the cathode.
- The electrolyte contains ions and conducts positive current from the anode to the cathode by ionic movement. The electrolyte contains both negatively charged ions called anions and positively charged ions called cations that are attracted to the anode and cathode, respectively. Moist soil is the most common electrolyte for external surfaces of the tank bottom, while water and sludge generally are the electrolytes for the internal surfaces.

4.1.2 There are many forms of corrosion. The two most common types relative to tank bottoms are general and pitting corrosion. In general corrosion, thousands of microscopic corrosion cells occur on an area of the metal surface resulting in relatively uniform metal loss. In pitting corrosion, the individual corrosion cells are larger and distinct anode and cathode areas can be identified. Metal loss in this case may be concentrated within relatively small areas with substantial areas of the surface unaffected by corrosion.




Figure 1—Electrochemical Corrosion Cell

4.1.3 The composition of the metal is a factor in determining which areas on a metal surface become anodes or cathodes. Differences in electrochemical potential between adjacent areas can result from uneven distribution of alloying elements or contaminants within the metal structure. Corrosion can also be caused by differences between weld metal, heat affected zone, and parent metal.

4.1.4 Physical and chemical properties of the electrolyte also influence the location of cathodic areas on the metal surface. For example, differing oxygen concentrations between areas on a steel surface may generate differences in potential. Areas with lower oxygen concentrations become anodic and areas with higher oxygen concentrations become cathodic. This can cause corrosion in areas where clay or other debris contact a steel tank bottom on a sand cushion or where a tank is set on two different types of soil (see Figure 2).




Figure 2—Oxygen Concentration Cell Caused by Rocks or Clay in Tank Cushion

4.1.5 Soil characteristics substantially affect the type and rate of corrosion on a structure in contact with soil. For example, dissolved salts influence the current carrying capacity of the soil electrolyte and help determine reaction rates at the anodic and cathodic areas. Moisture content, pH, oxygen concentration, and other factors interact in a complex fashion to influence corrosion.

4.2 CORROSION MECHANISMS

4.2.1 Stray Current Corrosion

Stray currents (also known as interference currents) travel through the soil electrolyte and on to structures for which they are not intended. Usually, the affected structure collects the interference currents from the electrolyte; the source of these currents is not electrically connected to the affected structure. As shown in Figure 3, stray current may enter an unprotected tank bottom and travel through the low resistance path of the metal to an area on the tank closer to the protected structure (pipeline). At this location, the current discharges

back into the electrolyte (soil) at point B with resultant metal loss. The most common, and potentially the most damaging, stray currents are direct currents. These currents are generated from grounded DC electric power systems including electric railroads, subways, welding machines, impressed current cathodic protection systems, and thermoelectric generators.

The severity of corrosion (metal loss) resulting from interference currents depends on several factors:

- Separation and routing of the interfering and affected structures and location of the interfering current source.
- Magnitude and density of the current.
- Quality or absence of a coating on the affected structures.
- The presence and location of mechanical joints having high electrical resistance.

Further information related to proper design to avoid stray currents, and detection and control of stray current corrosion, can be found in Sections 7 and 10.

4.2.2 Galvanic Corrosion

Galvanic corrosion occurs when two metals with different compositions (thus different electrolytic potentials) are connected in an electrolyte (usually soil). Current will flow from the more active metal (anode) to the less active metal (cathode) with accelerated attack at the anode. For example, galvanic corrosion can occur when a bronze check valve is joined to carbon steel piping or where stainless steel or copper pipe is connected to a carbon steel tank. In the pipe/steel tank example, the pipe becomes the cathode and the steel tank is the anode. Since current takes the path of least resistance, the most severe corrosion attack will occur in the area on the steel tank immediately adjacent to the pipe as shown in Figure 4. The extent of such a problem is dependent on several factors. The most significant factor is the relative areas of the cathode and anode and the relative position of the two materials in the galvanic series.

4.2.3 Internal Corrosion

Experience has revealed that corrosion may occur on the inside surface of a tank bottom. The extent or nature of corrosion depends on many factors associated with the composition of the fluid in contact with the steel bottom.

Major factors which influence the severity of corrosion include:

- Conductivity (a function of dissolved solids).
- Suspended solids.
- pH level.
- Dissolved gases such as CO_2 , H_2S , or O_2 .

Three major types of corrosion to be considered are general corrosion, pitting corrosion, and to a lesser extent in tanks, environmental cracking. For further discussion of internal corrosion mechanisms, see API Recommended Practice 652.

Further information related to proper design to avoid stray currents, and detection and control of stray current corrosion can be found in Sections 7 and 10.




Figure 3—Example of Stray Current Corrosion of an Unprotected Tank Bottom




Figure 4—Galvanic Corrosion

5 Determination of Need for Cathodic Protection

5.1 INTRODUCTION

The need for cathodic protection must be determined for all storage facilities. This section discusses parameters that must be considered when determining whether a steel above-ground storage tank bottom requires cathodic protection. If it is determined that corrosion will occur, adequate corrosion control procedures should be adopted to ensure metal integrity for safe and economical operation over the service life of the tank. The location of a facility or the presence of a leak detection system alone should not be used to determine the need for cathodic protection. The decisions governing the need for cathodic protection should be based on data from corrosion surveys; operating records; prior test results with similar tank systems in similar environments; national, state, and local code requirements; and the recommendations made within this document.

5.1.1 New Aboveground Storage Tanks

Corrosion control by cathodic protection for new above-ground storage tanks should be provided in the initial design and should be maintained during the service life of the system, unless detailed investigations indicate that cathodic protection is not required.

5.1.2 Existing Aboveground Storage Tanks

Studies should be made within a suitable time frame in accordance with API Standard 653 concerning the possible need for cathodic protection. When these studies indicate that corrosion will affect the safe or economic operation of the system, adequate corrosion control measures should be used.

5.1.3 Internal Cathodic Protection

Pure hydrocarbon fluids are usually not corrosive and do not require corrosion control for internal surfaces. However, based upon experience, internal corrosion may occur in aboveground storage tanks that have internal surfaces exposed to water, sediments, or other contaminants. Generally, coatings are used to reduce or eliminate corrosion on internal surfaces. For tanks in petroleum service, internal cathodic protection in conjunction with coatings has not gained widespread use, but under certain conditions it can be effective in protecting against corrosion at holidays in the coating. For more detailed information on internal cathodic protection, see NACE RP0575 and RP0388.

5.1.4 Limitations of External Cathodic Protection

Cathodic protection is an effective means of corrosion control only if it is possible to pass electrical current between the anode and cathode (tank bottom). Many factors can either reduce or eliminate the flow of electrical current and, therefore, may limit the effectiveness of cathodic protection in some cases or preclude its use in others. Such factors include:

- Foundations such as concrete, asphalt, or oiled sand.
- An impervious lining between the tank bottom and anodes such as in secondary containment systems.
- High resistance soil or rock foundations.
- Old storage tank bottoms left in place when bottom is installed.

These and other related factors are discussed in more detail in 5.3 and 5.4. It should be recognized that external cathodic protection has no effect on internal corrosion.

5.2 TANK HISTORY

5.2.1 Prior to determining the need for cathodic protection, a full evaluation of tank history is advised. The following items should be investigated and determined:

5.2.1.1 Tank Design/Construction History

The following items should be investigated and determined in the evaluation of tank design/construction history:

- Foundation design.
- Site plan, including tank farm layout.
- Construction dates.
- Soil properties and resistivity.
- Water table.
- Presence and type(s) of coatings or linings.
- Previous repairs.
- Change in soil conditions.
- Secondary containment membrane or impervious lining.
- Secondary bottom.
- Existing cathodic protection on nearby structures.
- Maintenance history.
- Expected life.
- Rectifier location.

5.2.1.2 Type of Service

The following items should be investigated and determined in the evaluation of types of service:

- Type of product stored.
- Product temperature.
- Presence and depth of water bottoms.
- Frequency of fill and discharge.

5.2.1.3 Inspection/Corrosion History

The following items should be investigated and determined in the evaluation of inspection/corrosion history:

- Tank inspection per API Standard 653.
- Corrosion rate records.
- Corrosion problems on nearby tanks.
- Corrosion problems on tanks of similar construction.
- Stray current problems.
- Design and performance of previous corrosion protection systems, if used.
- Structure-to-soil potential surveys.

5.2.1.4 Other Factors

The following items should be investigated and determined in the evaluation of other factors:

- Neighboring buried metallic structures.
- Neighboring cathodic protection systems.

5.2.2 If this evaluation indicates that external corrosion is a known or potential concern, then cathodic protection or other corrosion control measures should be used. If internal corrosion is known to be a problem, use of a lining should be considered (refer to API Recommended Practice 652); In certain cases, internal cathodic protection in conjunction with a lining may be applicable.

5.3 FOUNDATIONS AND SOIL CONDITIONS

5.3.1 Introduction

5.3.1.1 Due to a wide variety of surface, sub-surface, and climatic conditions, different types of foundations are constructed for aboveground storage tanks. The cushion material under the tank has a significant effect on external corrosion of the tank bottom and can influence the effectiveness and applicability of external cathodic protection. It is very important to ensure that there is no debris such as sticks, used welding rods, rocks, or clay in the cushion material. The cushion material particles should be fine and uniform. Tanks should be built on an elevated berm to allow adequate drainage away from the tank bottom. The use of fine particles will provide a more dense cushion to help reduce the influx and outflow of oxygen from the perimeter of the tank as it is emptied and filled. If large particle sizes are used, differential aeration corrosion may result at points where the large particles or debris contact the steel tank bottom. In this case, cathodic protection will not be effective in eliminating the pitting. There are a wide variety of cushion materials available, some of which may actually prevent the beneficial effects of cathodic protection. Conversely, there are situations where some of these materials, when properly selected and installed, can be beneficial in reducing corrosion to the extent that cathodic protection may not be needed.

5.3.1.2 Soil resistivity provides valuable information about the corrosivity of the material used under and around a tank. A general resistivity classification is given in Table 1. There are several techniques for measuring soil resistivity. A common method is described in ASTM G 57.

Table 1—General Classification of Resistivity

Resistivity Range, OHM-CM	Potential Corrosion Activity
<500	Very Corrosive
500-1,000	Corrosive
1,000-2,000	Moderately Corrosive
2,000-10,000	Mildly Corrosive
>10,000	Progressively Less Corrosive

5.3.1.3 The resistivity of the foundation material may be higher than the existing surrounding soil. However, corrosive soil beneath the high resistivity foundation material may contaminate the foundation fill by capillary action. Thus, resistivity of surrounding soil may be used to determine the probability of corrosion on the tank bottom. The results of soil resistivity surveys can be used to determine the need for cathodic protection. However, other properties of the soil (see 5.3.4) should also be considered.

5.3.2 Continuous Concrete Cushion

5.3.2.1 A properly designed concrete tank cushion constructed on a stable, properly prepared subsoil may be effective in eliminating intrusion of groundwater, soil-side corrosion, and the need for cathodic protection. Preparation of a stable soil to support the concrete slab is very important to ensure the continued integrity of the pad. Unstable soil may induce cracks in the slab through which water and contaminants can permeate to the steel tank bottom and provide a corrosive environment. The portion of the tank bottom in contact with a concrete ringwall will probably not be cathodically protected. Corrosion protection for this portion of the tank bottom can be enhanced by eliminating the ingress of water and other corrosive contaminants from the tank periphery.

5.3.2.2 Although corrosion from the soil may be prevented by a concrete pad, there may still be a collection of moisture between the tank bottom and the pad due to condensation, blowing rain or snow, or flooding due to inadequate drainage. Corrosion may occur due to this moisture accumulation. Cathodic protection is generally not considered an effective way to combat this corrosion. A free-draining concrete pad or ringwall and a seal around the periphery of the tank may be effective in eliminating the accumulation of moisture between the pad and the tank bottom where flooding in the dike area above the tank bottom does not occur. Non-continuous concrete tank foundation designs (for example, slotted pads) do not restrict the entry of oxygen. In situations where water may condense on the tank bottom or water is retained

above the concrete pad, accelerated atmospheric corrosion may occur.

5.3.2.3 Due to numerous complex factors that can affect the corrosion of a tank bottom underside in the presence of concrete, prediction of the propensity of corrosion in this case is extremely difficult. Thus, care should be observed with tanks on concrete pads since cathodic protection most likely will not help reduce any corrosion that might occur.

5.3.3 Continuous Asphalt Cushion

5.3.3.1 A cushion of new asphalt may provide many of the same advantages and disadvantages as a concrete cushion for reducing corrosion and eliminating the need for cathodic protection. The importance of proper support to prevent cracks and to prevent accumulation of water between the cushion and the tank bottom is possibly even more important for asphalt than for concrete because asphalt is not inherently alkaline and, therefore, does not have the potential of preventing corrosion in the event of cracks.

5.3.3.2 Asphalt degrades with time and can provide a path for water and dissolved chemicals to come into contact with the steel tank bottom, allowing corrosion to occur. Cathodic protection, if applied, may or may not aid in stopping corrosion when the asphalt becomes deteriorated. In fact, deteriorated asphalt may shield cathodic protection current in a manner similar to a disbonded coating on a pipeline. The condition of the external surface of the tank bottom as well as the asphalt can be determined if coupons are cut from the tank bottom.

5.3.4 Native Soil Cushion

5.3.4.1 Soil analysis is often a useful test for helping to determine whether the potential corrosion activity will be high enough to make cathodic protection necessary and whether cathodic protection will be a practical application to prevent corrosion. Determination of aggressive ions such as chlorides and sulfates along with measurement of pH and resistivity are helpful for further corrosion analysis. Table 2 provides a guideline for reviewing soil analysis data. The variety of particle sizes and chemical differences as discussed in 5.3.1 should also be considered.

5.3.4.2 Cathodic protection or other corrosion control measures should be considered when soil analysis data indicate that soil is corrosive.

5.3.5 Clean-Sand or Oiled-Sand Cushion

Clean sand is the most common material used as a cushion beneath storage tank bottoms. The use of clean sand alone normally does not eliminate the need for cathodic protection since corrosion may occur due to intrusion of water from rain, snow, or a shallow water table. Guidelines for the chemical

analysis of the sand for corrosive contaminants are discussed in 5.3.4.1. In some cases oil has been added to the sand for various reasons, including compaction and corrosion control.

Table 2—Guideline for
Reviewing Soil Analysis Data

Constituent	Corrosive	Very Corrosive
pH	5.0–6.5	< 5.0
Chlorides	300–1000 PPM	> 1000 PPM
Sulfates	1000–5000 PPM	> 5000 PPM

Experience in the industry is varied as to the effectiveness of oiled sand for corrosion control. The presence of oiled sand beneath tank bottoms has not been proven as an effective corrosion control measure and thus does not eliminate the need for cathodic protection and may cause cathodic protection to be less effective because of the higher resistivity of the oiled sand.

5.3.6 Contaminated Soil Cushion

5.3.6.1 In coastal areas, salt spray on tank surfaces will be washed down the sides of the tank by rain and will flow beneath the tank to contaminate the tank cushion. This also can occur in areas where fertilizers or chemicals may be in the atmosphere either from spraying or industrial operations. The tank cushion also can become contaminated by wicking action that can draw contaminants such as chlorides up from the water table. Cathodic protection is usually necessary for corrosion prevention in these situations.

5.3.6.2 If a leak occurs in a tank bottom, the leaking material also can influence corrosion on the external side. If water leaks from the tank, the environment under the tank may become more corrosive. If product leaks from the tank, it could create corrosion cells that did not previously exist or adversely affect the effectiveness of cathodic protection. A leak may wash away part of the foundation material and eliminate the contact of the tank bottom with the ground in some areas. Cathodic protection will not be effective in such areas. Additionally, the drainage properties of the foundation material may be deteriorated by a leak and allow water and contaminants to remain in contact with the tank bottom.

5.3.7 Crushed-Limestone or Clam-Shell Cushion

In some parts of the United States, the tank cushion consists of a layer of crushed limestone or clam shells. Such tank cushions without the use of cathodic protection have produced mixed results. The tank cushion should be fine and uniform, since differential aeration corrosion cells will cause pitting at contact areas between the large particles and the metal. The intrusion of water from rain or groundwater makes the environment under the tank alkaline, which may reduce corrosion. If contaminants are present in the cushion, or with

time infiltrate the cushion, corrosion may accelerate. Thus the use of crushed limestone or clam shells does not clearly eliminate the need for cathodic protection.

5.4 OTHER FACTORS AFFECTING CATHODIC PROTECTION

5.4.1 Contents of Tank

The contents of a storage tank can influence corrosion on tank bottoms. Accelerated corrosion can occur on the external surface of the bottom of heated tanks due to elevated temperatures if the area is wet. Storage tanks containing a hot product may require an increase in current density to achieve adequate protection on the external surface of the bottom. Conversely, sufficient heat could dry out a well-drained tank pad, thus increasing its resistivity and reducing the need for cathodic protection.

However, tank operators should be aware that if water penetrates the previously dried out tank pad (such as could be caused by above-average rainfall), the resistivity of the tank pad can decrease, developing a more corrosive condition. For this situation, the installation of a cathodic protection system should be considered.

5.4.2 Bottom Replacement

Replacement of tank bottoms is an accepted practice. Cathodic protection systems can be used to ensure long-term integrity of existing and replacement bottoms. The methods of installing replacement bottoms, secondary containment systems, and internal linings must be considered when determining the need for and the method of installation of a cathodic protection system. These factors relate to both existing and new cathodic protection systems and have a significant impact on the feasibility and effectiveness of cathodic protection. The effect of replacement bottoms and secondary containment on cathodic protection system design is discussed in 7.2.

5.4.3 Secondary Containment

5.4.3.1 There are a variety of methods available for secondary containment. These include, but are not limited to:

- a. Use of impervious clay pad in tank dike.
- b. Dual bottom tank design.
- c. Impervious nonmetallic membrane.

5.4.3.2 The use of secondary containment will reduce the environmental risk in the event of a leak. However, the use of certain secondary containment techniques may preclude the use of cathodic protection and in some cases may cause

accelerated corrosion of the tank bottom. An example of a double bottom secondary containment system is the installation of a new steel bottom over an existing steel bottom which has been repaired. If water or other electrolyte intrudes into the annulus, a galvanic cell may be formed which will cause the new steel tank bottom to corrode at an accelerated rate. In order to apply cathodic protection to a new tank bottom, anodes must be installed between the old and new bottom if sand or other substances that are conductive or that may become wet are used as fill material.

5.4.3.3 If a secondary containment system utilizing an impervious membrane lining is in place or is installed in a diked area prior to new tank construction, the option of cathodic protection becomes severely limited. Most cathodic protection systems are rendered ineffective because the liner acts as a barrier to the flow of electrical current necessary for protection. Another consequence of secondary containment involves the use of an impervious liner which may trap corrosive liquid, resulting in more severe corrosion of the tank bottom. There are advantages and disadvantages to using secondary containment linings. For a further discussion of the effect of secondary containment on cathodic protection design, refer to 7.2.

5.4.4 Thick-Film Internal Linings

Thick-film, laminated, and corrosion- and chemical-resistant linings are installed in tanks primarily to prevent internal corrosion and are frequently used as an alternative to replacing the steel bottom. As long as a corrosive condition exists under the tank, the lining, which is not designed for structural strength, could fail due to inadequate structural support. The use of a thick-film laminate or other type of internal lining should not be considered as sufficient justification to eliminate the need for external cathodic protection of tank bottoms.

6 Methods of Cathodic Protection for Corrosion Control

6.1 INTRODUCTION

Cathodic protection is a widely accepted method of corrosion control. Corrosion of aboveground steel storage tank bottoms may be reduced or eliminated with proper application of cathodic protection. Cathodic protection is a technique for preventing corrosion by making the entire surface of the metal to be protected act as the cathode of an electrochemical cell. There are two systems of cathodic protection:

- a. Galvanic.
- b. Impressed current.

Table 3—Partial Galvanic Series

Active or anodic	Metal	Volts
	Commercially pure magnesium	−1.75
	Magnesium alloy (6% Al, 3% Zn, 0.15%Mn)	−1.6
	Zinc	−1.1
	Aluminum alloy (5% Zinc)	−1.0
	Commercially pure aluminum	−0.8
	Mild steel (clean and shiny)	−0.5 to −0.8
	Mild steel (rusty)	−0.2 to −0.5
	Cast iron	−0.5
	Lead	−0.5
	Mild steel in concrete	−0.2
	Copper, brass, bronze	−0.2
	High silicon cast iron	−0.2
	Mill scale on steel	−0.2
Noble or cathodic	Carbon, graphite coke	+0.3

6.2 GALVANIC SYSTEMS

6.2.1 General

Galvanic systems use a metal more active than the structure to be protected to supply the current required to stop corrosion (see Table 3 for a partial galvanic series). The more active metal is called an anode, commonly referred to as a galvanic anode or a sacrificial anode. The anode is electrically connected to the structure to be protected and buried in the soil. A galvanic corrosion cell develops and the active metal anode corrodes (is sacrificed) while the metal structure (cathode) is protected. As the protective current enters the structure, it prevents the flow of corrosion current from the metal surface. Current then returns to the galvanic anode through a metallic conductor (see Figure 5). Metals commonly used as galvanic anodes in soil are magnesium and zinc in either cast or ribbon form. The anodes are usually distributed around the perimeter of the tank or buried beneath the tank bottom. Galvanic systems are normally applied only to small-diameter tanks.

6.2.2 Advantages of Galvanic Systems

There are several advantages of galvanic systems:

- No external power supply is required.
- Installation is relatively easy.
- Capital investment is low for small-diameter tanks.
- Maintenance costs are minimal.
- Interference problems (stray currents) are rare.
- Less frequent monitoring is required.

6.2.3 Disadvantages of Galvanic Systems

There are several disadvantages of galvanic systems:

- Driving potential is limited.
- Current output is low.

- Method is limited to use in low-resistivity soils.
- Method is not practical for protection of large bare structures.

6.3 IMPRESSED CURRENT SYSTEMS

6.3.1 General

The second method of applying cathodic protection to an aboveground storage tank bottom is to use impressed current from an external source. Impressed current systems use direct current usually provided by a rectifier attached to an AC power source. The rectifier converts alternating current to direct current. Direct current from the rectifier flows to the buried impressed current anode, from the anode through the soil electrolyte, and onto the tank bottom as shown in Figure 6.

6.3.2 Advantages of Impressed Current Systems

The advantages of impressed current systems include:

- Availability of large driving potential.
- High current output capable of protecting large structures.
- Capability of variable current output.
- Applicability to almost any soil resistivity.

6.3.3 Disadvantages of Impressed Current Systems

The disadvantages of impressed current systems include:

- Possible interference problems (stray currents) on foreign structures.
- Loss of AC power causes loss of protection.
- Higher maintenance and operating costs.
- Higher capital cost for small installations.
- Safety aspects of rectifier location.
- Safety aspects of negative lead connection.
- More frequent monitoring.




Figure 5—Galvanic Cathodic Protection With Sacrificial Anodes




Figure 6—Impressed Current Cathodic Protection

6.3.4 Cathodic Protection Rectifiers

A typical cathodic protection rectifier has two major components: (a) a step-down transformer to reduce the AC supply voltage, and (b) rectifying elements to convert AC input to DC output. Units may be obtained with either selenium or silicon rectifier elements. Silicon rectifiers are generally more efficient; however, they are more susceptible to damage from power surges. Therefore, protective devices should be considered for these units to prevent lightning damage. Because of decreased life at higher temperatures, selenium rectifiers are not recommended if ambient temperatures are expected to exceed 130°F (55°C).

6.3.5 Impressed Current Anodes

Impressed current anodes used in soil are made of materials such as graphite, steel, high silicon cast iron, or mixed metal oxides on titanium. Anodes are usually buried in a coke breeze backfill to extend their life and reduce circuit resistance. They may be located in remote groundbeds, distributed around the tank, installed underneath the tank, or installed in deep groundbeds.

7 Design of Cathodic Protection Systems

7.1 INTRODUCTION

7.1.1 Cathodic protection systems are designed and installed to prevent corrosion of a tank bottom by satisfying the requirements of one or more of the criteria listed in Section 8. In order to achieve the desired results, a cathodic protection system must be properly designed. The cathodic protection system should be designed after a study of the following items:

- Design and engineering specifications and practices.
- Operating procedures.
- Safety, environmental, and hazardous area requirements.
- Field testing.

7.1.2 In general, the design should provide adequate corrosion protection while minimizing installation, maintenance, and operation costs. The major objectives of cathodic protection designs for tank bottoms are to:

- Deliver and distribute sufficient current to the tank bottom to ensure that the criterion for protection is met.
- Provide a design life of the anode system and other equipment commensurate with the design life of the tank or provide for periodic replacement of anodes and maintenance of equipment.
- Provide adequate allowance for anticipated changes in current requirements with time.
- Place anodes, cables, rectifiers, and test stations where the possibility of physical damage is minimal.
- Minimize interference currents on neighboring structures.
- Provide sufficient monitoring points so measurements can be taken to determine that the protection criterion is met on the entire surface of the tank bottom.

7.1.3 There are many factors that must be considered in the design of both internal and external cathodic protection systems. Cathodic protection systems should be designed only by a person thoroughly familiar with cathodic protection practices.

7.1.4 Whenever possible, the design should be based on standard components provided by manufacturers regularly

engaged in the production of cathodic protection system components.

7.2 INFLUENCE OF REPLACEMENT BOTTOMS, LININGS, AND SECONDARY CONTAINMENT ON DESIGN

7.2.1 Barriers to Cathodic Protection

Cathodic protection is achieved by directing the flow of current from an anode to a cathode, resulting in protection of the cathode. Anything that acts as a barrier to the flow of current will prevent the application of cathodic protection. Secondary containment and replacement bottoms can have such an effect if not properly considered.

7.2.2 Tank Bottom Replacement

Replacement of tank bottoms is an accepted practice. Whether the old bottom is left in place or removed has a significant impact on the types of cathodic protection systems that are feasible for corrosion control of the new bottom (see 7.2.4.3).

7.2.3 Considerations When Secondary Containment is Used in a Diked Area

7.2.3.1 Impervious Membrane Lining

One method used to provide secondary containment to line the entire diked area with an impervious membrane. An existing membrane under a tank or one proposed for a new tank can have a significant impact on the choices and design of a cathodic protection system. In either case, anodes must be placed between the membrane and the tank bottom in order for cathodic protection to work (see Figure 7). However, if a layer of bentonite clay is installed beneath the tank for secondary containment, experience has shown that it will not significantly affect the operation of a conventional cathodic protection system.

7.2.3.2 Existing Multiple or Single Tanks With a Dike Lining

To install a cathodic protection system on an existing tank in a diked area that is lined from dike wall to dike wall and under the tank with an impervious membrane, one option is to bore under the tank at a very shallow angle and install

anodes under the tank. In order to obtain adequate protection, an impressed current system probably would be required. This would be feasible only if there was sufficient depth between the tank bottom and the membrane that the integrity of the membrane would not be compromised. At this time, there is limited experience with this type of system.

7.2.3.3 New Multiple or Single Tanks with a Dike Lining

New tanks in a diked area lined with an impervious lining can be equipped with a network of shallow anodes or a grid of ribbon anodes which would be placed between the liner and the tank bottom during construction. Such an arrangement could be an impressed current system or a galvanic system. However, a geosynthetic clay liner may be used and a conventional cathodic protection system installed.

7.2.4 Replacement or Repair of Steel Tank Bottoms

7.2.4.1 Replacement or repair of steel tank bottoms is a common practice since the shell of a tank typically will far outlast the bottom. Linings are frequently installed in tanks to protect against internal corrosion. The installation of a new steel tank bottom is also a very common practice. An acceptable and commonly used method of replacing tank bottoms can be found in API RP 575 and API Standard 653.

7.2.4.2 The method of repair or bottom replacement is of major importance in determining if cathodic protection should be installed and whether or not an effective cathodic protection system can be installed.

7.2.4.3 If an existing tank bottom is protected by cathodic protection and/or if cathodic protection is planned for the new bottom (by means of deep or shallow groundbeds), the old bottom will have to be completely removed. If it is not removed, the old bottom forms a shield that collects the cathodic current flowing through the ground and prevents cathodic protection of the new bottom (see Figure 8). Unless cathodic protection is installed between the two steel bottoms, or the old bottom is removed, electrically isolated, or coated with a nonconductive material, a galvanic cell can develop between the old and new bottom. Industry experience has shown that if a conductive electrolyte exists between bottoms, the current flow and metal loss will be from the new bottom, resulting in premature failure of the new bottom.




Figure 7—Impervious Membrane Beneath Storage Tank




Figure 8—New Steel Bottom on Top of Old Bottom

7.2.5 Effects of Impermeable Membrane Secondary Containment Systems

7.2.5.1 The installation of a secondary containment membrane between the old and new bottom is an alternative practice. There are advantages and disadvantages to this practice.

7.2.5.1.1 Advantages

There are several advantages to the installation of a secondary containment system:

- a. Provides a means of detecting and containing leaks and preventing ground contamination if leaks occur.
- b. Eliminates the natural current flow between the old bottom and the new bottom, thus reducing the accelerated failure of the new bottom due to galvanic corrosion.
- c. May reduce entry of groundwater into the space between the bottoms. The integrity of tank-to-membrane seals is critical in this case.

7.2.5.1.2 Disadvantages

Installing a secondary containment system could be disadvantageous for the following reasons:

- a. Makes the future addition of cathodic protection virtually impossible.
- b. Membrane acts as a basin to contain water or any other electrolyte that might wet the sand between the old and new bottoms, thus increasing corrosion rates.
- c. Could entrap hydrocarbon products, thereby requiring extra precautions for hot work.

7.2.5.2 To keep the advantages and eliminate or reduce the adverse effects of a membrane in the old bottom, install a cathodic protection system in the space between the old bottom and the new bottom. Such a system could consist of a grid of ribbon anodes embedded in the sand between the old bottom and the new bottom. The connecting wires project through the membrane and through a sealed bulkhead fitting (in the old shell portion) to be connected directly to the tank or through a test station. This type of system would have to be installed at the time the bottom is replaced. If unexpected anode wastage occurs, remedial measures to replace anodes cannot be easily accomplished. The advantages of this system include the following:

- a. The need for future cathodic protection system installation is decreased.
- b. The membrane acts as a barrier to current flow, protecting the old bottom and directing all current flow toward the new bottom.

c. As long as the sand stays dry, corrosion rates and current flow would be low as a result of the high resistivity of the sand.

d. Corrosion would tend to increase if the sand became wet; however, the resistivity of the sand would be much lower, thus more current would flow and cathodic protection would increase (a self-governing system).

e. The cost of the anodes is a small fraction of the total cost.

7.3 EXTERNAL CATHODIC PROTECTION

7.3.1 Introduction

The purpose of this section is to recommend procedures for designing cathodic protection that will effectively control external corrosion by satisfying one or more of the criteria listed in Section 8 for the intended service life of the above-ground storage tanks.

7.3.2 Design Considerations

In the design of cathodic protection, the following items should be considered:

- a. Recognition of hazardous conditions prevailing at the proposed installation site and the selection and specification of materials and installation practices that will ensure the safe installation and operation of the cathodic protection system.
- b. Specification of materials and installation practices to conform with applicable codes, such as National Electrical Manufacturers Association standards, NACE recommended practices, and federal, state, and local regulations.
- c. Selection and design of the cathodic protection system for optimum economy of installation, maintenance, and operation.
- d. Selection and specification of materials and installation practices that will ensure dependable operation throughout the intended service life of the cathodic protection system.
- e. Selection of a design to minimize excessive protective currents or earth potential gradients that can detrimentally affect the tanks, piping, coating, or neighboring buried or submerged metallic structures.
- f. Provisions for monitoring the cathodic protection system operation.

7.3.3 Information Useful for Design

Information that is useful for design can be divided into three categories:

- a. Specifications and practices.
- b. Site conditions.
- c. Field survey, corrosion test data, and operating experience.

7.3.3.1 Specifications and Practices

Information pertaining to these specifications or practices may prove useful:

- a. Site plan and system layout.
- b. Construction dates.
- c. Tank design information.
- d. Pumps and power supply.
- e. Coatings.
- f. Corrosion control test stations.
- g. Electrical isolation.
- h. Electrical bonds.
- i. Electrical conduit routing.
- j. Electrical area classification boundaries.

7.3.3.2 Site Conditions

These factors relating to site conditions may be useful in designing cathodic protection:

- a. Existing and proposed cathodic protection systems.
- b. Possible interference sources (stray current).
- c. Special environmental conditions.
- d. Depth of bedrock.
- e. Depth of frost line.
- f. Neighboring buried metallic structures (including location, ownership, and corrosion control practices).
- g. Structure accessibility.
- h. Power availability.
- i. Feasibility of electrical isolation from foreign structures.
- j. Secondary containment system, if any.
- k. Areas of poor water drainage.

7.3.3.3 Field Survey, Corrosion Test Data, and Operating Experience

The following information may also be useful:

- a. Protective current requirements to meet applicable criteria.
- b. Electrical resistivity of the electrolyte (soil).
- c. Electrical continuity of the system.
- d. Electrical isolation of the system.
- e. Coating integrity.
- f. Leak history of similar structures in the area.
- g. Deviation from construction specifications.
- h. Existence of stray current.
- i. Other maintenance and operating data.

7.3.4 Considerations That Influence Selection of the Type of Cathodic Protection System

7.3.4.1 The following factors influence the selection of a cathodic protection system:

- a. Size and number of tanks to be protected.
- b. Current required.

- c. Soil conditions such as resistivity, chemical composition, aeration, and pH.
- d. Possibility of cathodic protection interference on adjacent structures.
- e. Future developments and extensions to the storage system.
- f. Cost of cathodic protection equipment, installation, operation, and maintenance.
- g. Existing or proposed secondary containment system.

7.3.4.2 Several options are available for the protection of one or more tanks, including:

- a. Shallow anodes installed around the periphery of the tank.
- b. Anodes installed directly under the tank prior to construction.
- c. Boring under the tank at an angle so that anodes can be installed under the tank in a pattern that will provide adequate protection.
- d. Use of a deep groundbed.

7.3.5 Types of Cathodic Protection Systems

7.3.5.1 Galvanic Anode System

7.3.5.1.1 Galvanic systems use galvanic anodes which can be made of materials such as magnesium or zinc in either cast or ribbon form. These are installed either bare or packaged in a special backfill. The anodes are connected to the system, either singly or in groups. Galvanic anodes are limited in current output by the system-to-anode driving voltage and the circuit resistance. It may be more economical to cathodically protect bare, poorly coated, or very large structures with impressed current-type systems. Galvanic cathodic protection systems may be more economical on small-diameter tanks. (Re: NACE RP0193.)

7.3.5.1.2 Three galvanic anode materials are commonly used for soil installations:

- a. High potential magnesium alloys.
- b. Standard magnesium alloy.
- c. Zinc.

7.3.5.1.3 Magnesium and zinc anodes prepackaged in special backfill are readily available in a number of size and weight configurations to meet various current output and anode life design requirements. The use of a special backfill with anodes is desirable for installation in soil environments. Special backfill, consisting of a proper mixture of gypsum, bentonite, and sodium sulfate, promotes anode efficiency, lengthens anode life, and keeps the anode environment moist.

7.3.5.1.4 The number of anodes required to provide cathodic protection for aboveground storage tanks depends upon total current requirements and the expected individual anode discharge rate in the soil. In placing the anodes, current distribution factors should also be considered. Sometimes it is

advantageous to consider the use of different sizes of anodes so that more anodes will be required and give better current distribution. Typically, better current distribution and more uniform polarization is obtained by distributing anodes uniformly around the tank or under the tank for new construction.

7.3.5.2 Impressed Current System

7.3.5.2.1 Anodes

7.3.5.2.1.1 Impressed current anodes can be of materials such as, but not limited to, graphite, high silicon cast iron, steel, platinized metals, magnetite, and mixed metal oxides. These anodes are installed either bare or in special backfill material (usually coke breeze). They are connected with an insulated conductor either singly or in groups to the positive terminal of a direct current source. The structure is connected to the negative terminal of the direct current source.

7.3.5.2.1.2 Graphite, high silicon cast iron, or mixed metal oxide anodes are generally preferred for soil installations. Platinized niobium, tantalum, and titanium are best suited for water rather than soil installations.

7.3.5.2.1.3 Each anode material has an optimum current density that provides maximum anode service life. Anodes may be located in remote groundbeds, located in deep groundbeds, or distributed closely about or under the structure to be protected. A proper groundbed design should:

- Avoid physical interference with existing facilities.
- Provide uniform current distribution.
- Avoid stray current interference with off-site structures.

7.3.5.2.1.4 The number of anodes in a particular cathodic protection design will be determined by total current requirements of the structures to be protected and the optimum current density of the anode material selected. For a distributed anode design, additional anodes may be installed to provide more uniform current distribution and to provide allowance in case of isolated anode connection failures or partial anode depletion.

7.3.5.2.2 Current and Voltage Requirements

7.3.5.2.2.1 For optimum design, the current required for cathodic protection should be calculated using the results of current requirement tests. However, in lieu of a current requirement test, the generally accepted protective current density is between 1 and 2 milliamperes per square foot at ambient conditions. If a current requirement test is used, it can be performed only on existing tanks. It is conducted using a tem-

porary anode bed (groundbed) and an appropriate source of direct current (Figure 9). The temporary groundbed is typically positioned in the soil near the perimeter of the tank. Depending on the current required, the power source can vary from a 12-volt storage battery to a 300-amp welding unit.

7.3.5.2.2.2 Current requirement tests are conducted by forcing a known amount of current from the temporary anode bed through the soil and onto the tank to be protected. The degree of protection at various locations around the tank, and under the tank center if possible, is evaluated using potential measurements. This testing allows approximation of the current required to protect the tank. Current requirement tests should be conducted with an adequate liquid level in the tank to maximize contact of the tank bottom with the cushion material.

7.3.5.2.2.3 The voltage necessary to drive the required amount of current depends largely on the number and location of anodes and on the resistivity of the soil. Since the current is generally known from a current requirement test or is estimated, the voltage requirement can be calculated using Ohm's law ($E = I \times R$) if the resistance of the circuit is known. The resistance can be estimated in several ways:

- From existing impressed current systems similar to the one to be installed.
- From current requirement tests as described above if the test groundbed is similar to the final one.
- From soil resistivity tests, the anode-to-earth resistance can be calculated using a variation of Dwight's equation (see NACE 51011). The anode-to-earth resistance is generally the dominant part of the overall circuit resistance in an impressed current system.




Figure 9—Current Requirement Test Setup

7.3.5.2.3 Rectifier Selection

The rectifier output capacity selected will depend upon the following factors:

- Estimated or measured current requirements of the structure to be protected.
- The voltage needed to cause current to flow from the anodes to the buried structure.
- Rectifiers with a moderate excess capacity (typically 10–50 percent) should be selected to allow for adjustments during the life of the cathodic protection system and to prevent damage due to voltage overloads. Care should be observed if the excess rectifier capacity will be used to drive the anodes. Increasing the current output of the anodes above the manufacturer's rating will cause a decrease in anode life.

7.3.6 Electrical Isolation

7.3.6.1 Insulating devices consisting of flange assemblies, pre-fabricated insulating joints, or couplings should be installed where electrical isolation of the system is required to facilitate the application of corrosion control. These devices should be properly rated for temperature, pressure, and dielectric strength. Insulating devices should not be installed in enclosed areas where combustible atmospheres are normally present.

7.3.6.2 Electrical grounding of electrical equipment is an essential element in personnel safety. It may not be practical or desirable to electrically isolate storage tanks from each other or adjacent plant equipment due to the probable interconnection via a grounding grid. Attachment of auxiliary equipment such as electronic gauges, mixer motors, and lighting may also preclude the possibility of effectively maintaining isolation. When installing a cathodic protection system for a tank bottom, it should be recognized that some of the current may also be collected on adjacent buried metallic equipment.

7.3.6.3 Lightning arresters and fault current protection devices installed at insulators should be of a size suitable for short term, high current loading. Where insulating devices are installed in areas of known or suspected influence from high voltage alternating current (HVAC) power lines, precautions should be taken to ensure that the AC potentials across such devices do not present a hazard to personnel. Refer to the latest revision of NACE RP0177.

7.4 INTERNAL CATHODIC PROTECTION

7.4.1 The design of an internal cathodic protection system is complicated because of the variation in the level of the accumulated corrosive medium (usually water). In addition, the presence of sludge and other contaminants could have a detrimental effect on the performance of the cathodic protection system. There are many factors which influence the

design of an internal cathodic protection system. A few of these factors are listed below:

- Condition and type of coating (if any).
- Minimum and maximum water level in tank.
- Compatibility of stored liquid with anodes and cables.
- Internal inspection interval of tank, which affects design life.

7.4.2 Because of the many variables associated with design of internal cathodic protection systems for petroleum storage tanks, the use of these types of systems is limited and industry-wide practices do not exist. It is recommended that Sections 4 and 5 of NACE RP0575 be consulted when designing similar systems for aboveground hydrocarbon storage tank bottoms. In addition, NACE RP0388 should be consulted for design information for impressed current systems.

8 Criteria for Cathodic Protection

8.1 INTRODUCTION

The purpose of this section is to list criteria for cathodic protection that will indicate when adequate cathodic protection has been achieved. The selection of a particular criterion for achieving the objective depends, in part, on prior experience with similar structures and environments wherein the criterion has been used successfully.

8.2 PROTECTION CRITERIA

8.2.1 There are several criteria for determining if adequate cathodic protection has been achieved on steel and iron structures. For a more detailed description, refer to the latest edition of NACE RP0169.

8.2.2 The following criteria were developed through laboratory experiments or were determined empirically by evaluating data obtained from successfully operated cathodic protection systems. It is not intended that persons responsible for corrosion control be limited to these criteria if it can be demonstrated that the control of corrosion can be achieved by other means.

8.2.2.1 A negative (cathodic) potential of at least 850 mV with the cathodic protection current applied. This potential shall be measured with respect to a saturated copper/copper sulfate reference electrode (CSE) contacting the electrolyte. Voltage drops other than those across the tank bottom-to-electrolyte boundary must be considered for valid interpretation of this voltage measurement.

Note: *Considered* is understood to mean the application of sound engineering practice in determining the significance of voltage drops by methods such as:

- Measuring or calculating the voltage drop(s),
- Reviewing the historical performance of the cathodic protection system,
- Evaluating the physical and electrical characteristics of the tank bottom and its environment, and
- Determining whether or not there is physical evidence of corrosion.

8.2.2.2 A negative polarized potential of at least 850 mV relative to a CSE. (One common method of measuring polarized potential is by using the “instant off” technique.)

8.2.2.3 A minimum of 100 mV of cathodic polarization measured between the tank bottom metallic surface and a stable reference electrode contacting the electrolyte. The formation or decay of this polarization can be measured to satisfy this criterion.

8.3 MEASUREMENT TECHNIQUES

8.3.1 The standard method of determining the effectiveness of cathodic protection on a tank bottom is the tank-to-soil potential measurement. These measurements are performed using a high-impedance voltmeter and a stable, reproducible reference electrode contacting the electrolyte. These measurements are commonly made with the reference electrode in the soil at the perimeter of the tank as shown in Figure 10. Measurements at the perimeter of the tank may not represent the tank-to-soil potential of the center of the tank bottom. Methods to monitor tank-to-soil potentials under the center of the tank are discussed in 9.4.

8.3.2 The tank-to-soil potential measurements are typically taken with current applied; however, correction for IR drop(s) in the soil must be made. Correction for the IR drop in the soil is often necessary for measurements made at the tank perimeter even if the reference electrode is placed immediately adjacent to the tank. This is especially true if distributed anodes are close to the tank since the perimeter of the tank may be within the electric field gradient of the anodes.

8.3.3 The value of the IR drop and the methods of correcting for it should be determined by using sound engineering practices. Interrupting the flow of current at the rectifiers using the “instant-off” technique is a common method. The IR drop, once determined, can be used for future tests at the same location if conditions remain similar.

8.3.4 Consideration should be given to monitoring the actual structure-to-soil potential under the tank by use of a permanently installed reference electrode or by inserting a reference electrode under the tank through a perforated tube (see 9.4). Tank bottom surface area contacting the tank cushion may vary with the tank content level. Since this condition can cause variations in tank-to-soil potentials, level of tank content should be considered at the time of the survey. For more detailed information, see NACE Publication 10A190.




Figure 10—Potential Measurement Schematic

8.4 ALTERNATIVE REFERENCE ELECTRODES

Other standard reference electrodes may be substituted for the saturated copper/copper sulfate reference electrode. Three commonly used reference electrodes are listed in Table 4 along with their voltage equivalent to -0.85 volt referred to a saturated copper/copper sulfate reference electrode.

Table 4—Commonly Used Reference Electrodes

Reference Electrodes	Voltage
Saturated KCl calomel	-0.78
Silver/silver chloride (used in sea water)	-0.80
Zinc	$+0.25$

9 Installation of Cathodic Protection Systems

9.1 INTRODUCTION

9.1.1 The purpose of this section is to recommend procedures for the installation of cathodic protection systems that will control corrosion of the tank bottom if design considerations recommended in Section 7 have been followed.

9.1.2 The installation of cathodic protection systems should be under the supervision of trained and qualified personnel to ensure that the installation is made in strict accordance with the drawings and specifications. Exceptions may be made only with the approval of the owner, operator, or personnel qualified by the owner or operator.

9.2 GALVANIC ANODE SYSTEMS

9.2.1 Packaged anodes should be inspected to ensure integrity of the container and should be kept dry during storage. If individually packaged anodes are supplied in waterproof containers, that container must be removed before installation. Electrical continuity between the anode and lead wire should be tested without compromising the integrity of the package. Packaged galvanic anodes should be back-filled with compacted native soil. Figure 11 shows a typical galvanic anode installation.

9.2.2 Where anodes and special backfill are provided separately, anodes should be centered in the special backfill, which should be compacted prior to backfilling with native soil.

9.2.3 When galvanic anodes are used to protect internal surfaces of tank bottoms, they can be either bolted or welded to the tank bottom. The connection should be coated, but care should be taken not to coat or paint the anode.

9.2.4 Where a ribbon-type anode is used between tank bottoms, it is generally installed in clean, dry sand without special backfill. Ribbons should be carefully straightened and made to lie flat so that the anode will not contact the steel bottom.




Figure 11—Typical Galvanic Anode Installation

9.2.5 Care should be taken so that lead wires and connections are not damaged during backfill operations. Lead wires should have enough slack to prevent strain. Anodes should not be carried or lowered into the excavation by the lead wire.

9.3 IMPRESSED CURRENT SYSTEMS

9.3.1 Introduction

9.3.1.1 Impressed current anodes should be inspected for defects, conformance to anode material specification, size and length of lead wires, and to ensure that the anode cap, if used, is secure. Care must be exercised to avoid cracking or damaging anodes during handling and installation. Cracked anodes should not be used. Lead wires should be carefully inspected for defects in insulation. Care must be taken to avoid damage to insulation on wire. Defects in the lead wire must be repaired, or the anode must be rejected.

9.3.1.2 Impressed current anodes can be buried vertically, horizontally, angled, or in deep holes. Impressed current anodes are typically installed in carbonaceous backfill such as coke breeze. If the backfill is installed properly so that there are no voids around the anode, much of the current reaching the anode is conducted to the backfill by electrical contact. This promotes consumption of the backfill instead of the anode and substantially lengthens the effective anode life. Carbonaceous backfill also tends to reduce total circuit resistance by lowering anode-to-soil resistance.

9.3.1.3 The principal points to be observed in the installation of impressed current anodes are:

- The coke breeze must be correctly installed because loose backfill can result in high resistance and shortened anode life. The anode should be centered in the coke breeze. Premature anode failure will occur if the anode comes in contact with the soil.
- Buried connections must be protected with extreme precautions against the entrance of any moisture, because any discharge of current to earth from the cable will destroy it very rapidly.
- Care should be taken to protect the cable connection to the anode; this is the weak point in all anodes, and the joint is prone to failure by the entrance of moisture through even the tiniest crack.
- Anodes and cable should be installed at a sufficient depth to protect against accidental damage. It must be remembered that the anode lead may be severed by corrosion if there is the slightest break in its insulation.

9.3.2 Shallow Groundbed Installation

9.3.2.1 Figure 12 shows an example of a shallow groundbed installation. For a typical vertical anode installation, the hole is excavated 8–12 inches in diameter by approximately 10–20 feet deep. Power auger equipment is used where available if both the terrain and right of way will permit. The anode is centered in the opening and properly installed backfill is carefully tamped when necessary. Many anodes come pre-packaged with compacted backfill in nominal 8-inch-diameter cans.

9.3.2.2 Sometimes it is necessary to install an anode in a location where rock is encountered at a shallow depth, or where soil resistivity increases markedly with depth. Such sites can be coped with by a horizontal installation of anodes. A ditch is excavated to whatever depth is practical, and a horizontal column of coke breeze is laid therein, usually square in cross-section. The anode is laid horizontally in the center of this column.

9.3.2.3 In some instances, to improve current distribution to the center of the tank bottoms, it may be desirable to install anodes in holes which are drilled at an angle under the perimeter of the tank bottom. Canistered anodes may be beneficial in such an installation to ensure that the anode remains centered in the coke breeze column.

9.3.3 Deep Groundbed Installation

In situations where a deep groundbed similar to that shown in Figure 13 is required, refer to the latest edition of NACE




Figure 12—Typical Shallow Groundbed Installation

RP0572. Prior to installation of a deep groundbed, it is important to consider the environmental aspects of the installation since the groundbed may be located through underground aquifers. It is often appropriate to provide an internal and external casing seal to maintain separation between surface and subsurface environments.

9.3.4 Rectified Installation

9.3.4.1 The rectifier or other power source should be installed so that the possibility of damage or vandalism is minimized.

9.3.4.2 Rectifiers and associated wiring should comply with local, state, and national electrical codes and electrical area classification per API Recommended Practice 500. An external disconnect switch on AC wiring should be provided. The rectifier case should be properly grounded.

9.3.4.3 Lead wire connections to the rectifier must be mechanically secure and electrically conductive. Before the power source is energized, it must be verified that the negative lead is connected to the structure to be protected and that the positive lead is connected to the anodes.

CAUTION: If the leads are reversed, with the positive lead mistakenly attached to the tank, the tank bottom will serve as an anode and rapid corrosion failure can result.

9.3.4.4 A powder weld connection (for example, Cadweld, Thermite, or equivalent) is the preferred means for connecting the negative rectifier lead wire to the structure to be protected; however, good mechanical connections may be substituted if necessary. All positive cable connections and wire splices should be carefully waterproofed and covered with electrical insulating material. If mechanical connections are used, they should not be buried.

9.3.5 Cable Installation

9.3.5.1 All underground wire attached to the positive rectifier terminal is at a positive potential with respect to ground. If not completely insulated, the wire may discharge current (act as an anode), which will result in corrosion of the wire

and rapid failure of the cathodic protection installation. Therefore, all anode lead wires, header cables, and any wire splices should be carefully inspected prior to backfilling. Cable can be installed by plowing if proper precautions are taken. Backfill should be free of sharp stones or other material that could damage wire insulation. Consideration should be given to installing cable in rigid conduit in areas subject to frequent excavation or where cable insulation is prone to damage by rodents.

9.3.5.2 Underground splices of the header cable (positive lead wire) to the groundbed should be avoided. Connections between header cable and anode lead wires should be mechanically secure and electrically conductive. Sufficient slack should be left to avoid strain on all wires. All splices and connections must be sealed to prevent moisture penetration so that electrical isolation from the environment is ensured.

9.4 CORROSION CONTROL TEST STATIONS, CONNECTIONS, AND BONDS

9.4.1 The structure and test lead wires should be clean, dry, and free of foreign materials at points of connection.




Figure 13—Commonly Installed Deep Groundbed

Connections of test lead wires to the structure must be installed so that they will remain mechanically secure and electrically conductive. A preferred method from the electrical standpoint is the use of a powder weld connection (for example, Cadweld, Thermite, or equivalent). However, this method is not recommended in areas where a combustible atmosphere may exist during the attachment process.

9.4.2 Attention must be given to the manner of installing test lead wires for corrosion control testing to avoid affecting the physical strength of the structure at the point of attachment.

9.4.3 All test lead wire attachments and all bare test lead wires should be coated with an electrically insulating material. Test lead wires should be color coded or otherwise permanently identified. Sufficient slack should be left to avoid strain on all wires. Damage to insulators must be avoided, and proper repairs must be made if damage occurs.

9.4.4 One of the problems associated with monitoring cathodic protection systems on tank bottoms is the inability to place a portable reference electrode in close proximity to the underside. For new tank construction, the problem of testing the tank-to-soil potential at the center can be solved by installing either of the following:

- a. Permanent reference electrodes and lead wires underneath the tank cushion to the perimeter of the tank where they can be terminated in a test station for future use in testing (Figure 14).
- b. A perforated polyvinyl chloride (PVC) or fiber reinforced plastic (FRP) pipe for use in profiling the tank-to-soil potential from the perimeter to the center.




Figure 14—Permanently Installed Reference Electrode and Test Station

9.4.5 Where permanent reference electrodes are specified, installation should be per manufacturer's recommended procedures.

9.4.6 If a tank is scheduled for bottom repair or replacement, consideration should be given to the installation of one or more permanent reference electrodes under the tank bottom. For existing tanks not scheduled for such repairs, installation of permanent reference electrodes can be accomplished by using a water jetting or mechanical procedure. A hole can be bored from the perimeter of the tank to the center of the tank and a perforated PVC or FRP pipe installed underneath the existing tank (Figure 15). The perforated pipe is used and installed in a manner to provide electrical continuity between the soil outside the tube and the electrode inside the tube for the entire length. A submersible copper-copper sulfate reference electrode can be inserted into the pipe, using a nonmetallic electrician's fish tape or small diameter PVC pipe, to obtain a profile of the tank-to-soil potential across the tank bottom. If a metallic device is used to insert the reference electrode, it should be removed before readings are taken.

CAUTION: Care must be exercised when using water jetting techniques to prevent undermining of the tank foundation. Mechanical means of tube insertion should be carefully controlled to avoid damaging the tank bottom.

9.4.7 It is common to contact the tank with a knife or ice pick when taking a tank-to-soil potential measurement. This repeated action can cause early failure of the tank's paint system. Permanently installed test leads, grounding lugs, or short pieces of cable or tubing can avoid this and also readily identify the normal monitoring locations.

9.4.8 If isolating devices are required, inspection and electrical measurements should be made to ensure that electrical isolation is effective and meets the requirements for cathodic protection.

9.4.9 Electrical devices isolated from the liquid storage system for cathodic protection purposes should be provided with safety grounds in accordance with applicable electrical codes.

10 Interference Currents

10.1 INTRODUCTION

10.1.1 The purpose of this section is to identify sources of interference currents and to recommend practices for the detection and control of these currents. It should be noted that the installation of a new impressed current cathodic protection system may cause interference with neighboring structures.

10.1.2 Interference is the undesirable discharge of current from a structure caused by the application of electrical current from a foreign source. Interference is normally from a DC source, although AC can also cause interference problems. A more detailed description can be found in 4.2.1. Consult the




Figure 15—Perforated Pipe Installed for Reference Electrode

latest edition of NACE RP0169 for more information on interference currents.

10.2 SOURCES OF INTERFERENCE CURRENTS

10.2.1 Constant Current

These sources have essentially constant direct current output. The most common sources are rectifiers energizing nearby cathodic protection systems.

10.2.2 Fluctuating Current

These sources have a fluctuating direct current output. The greatest sources of stray current are the electric railway, rapid transit system, underground mining electrical systems, and welding machines.

10.3 DETECTION OF INTERFERENCE CURRENTS

During corrosion control surveys, personnel should be alert for electrical or physical observations that could indicate interference from a neighboring source. These include:

- A negative shift of the structure-to-soil potential on the affected structure at a point where current is picked up from the foreign direct current source.
- A positive shift of the structure-to-soil potential on the affected structure at a point where current may be discharged from the affected structure.
- Localized pitting in areas near or immediately adjacent to a foreign structure.

10.4 CONTROL OF INTERFERENCE CURRENTS

10.4.1 There are three fundamental approaches to resolving an interference problem:

- Design which aims at minimizing exposure.
- Bonding to provide a metallic return of current collected by a foreign structure.
- Auxiliary drainage of the collected current by the use of sacrificial anodes.

10.4.2 Interference problems can be prevented and resolved by participation in local corrosion coordinating committees. When interference effects are observed, the committee can often provide information on the source of the interference currents. If no local committee exists, refer to NACE TPC Publication 11.

Note: Contact NACE International for information regarding these committees.

11 Operation and Maintenance of Cathodic Protection Systems

11.1 INTRODUCTION

11.1.1 The purpose of this section is to recommend procedures and practices for energizing and maintaining continuous, effective, and efficient operation of cathodic protection systems.

11.1.2 Electrical measurements and inspections are necessary to determine that protection has been established according to applicable criteria and that each part of the cathodic protection system is operating properly. Conditions that affect

protection are subject to change with time. Corresponding changes may be required in the cathodic protection system to maintain protection. Periodic measurements and inspection are necessary to detect changes in the cathodic protection system. Conditions may exist where operating experience indicates that testing and inspections should be made more frequently than recommended herein.

11.1.3 Care should be exercised in selecting the location, number, and type of electrical measurements used to determine the adequacy of cathodic protection. If tanks are empty, there may be large areas of the bottoms which are not in contact with the underlying soil. Potential surveys, in this case, may give misleading information.

Bottom-to-electrolyte potential readings may indicate adequate cathodic protection for the portion of the tank bottom in contact with the soil but when the tank is full and all of the tank bottom is in contact with the soil, protection may be insufficient. Therefore, potential surveys should be conducted with an adequate level in the tank to maximize contact of the tank bottom with the cushion material.

11.1.4 If cathodic protection devices are shut off while working on storage tanks, the system should be re-energized as soon as possible to avoid corrosion damage during extensive maintenance periods.

11.2 SAFETY

11.2.1 All impressed current systems must be designed with safety in mind. Care must be taken to ensure that all cables are protected from physical damage and the possibility of arcing.

11.2.2 Rectifiers and junction boxes must meet regulatory requirements for the specific location and environment in which they are installed. Such locations shall be determined by reviewing local, state, federal, and prevailing industrial codes.

Consideration should be given to locating isolating devices, junction boxes, and rectifiers outside of hazardous areas in case sparks or arcs occur during testing.

11.2.3 In order to prevent arcing, care must be exercised when working on breakout piping attached to tanks with cathodic protection applied. When cathodic protection systems are turned off, sufficient time must be allowed for depolarization before opening connections. Bonding cables must be used when parting breakout piping joints.

11.2.3.1 Additional guidance regarding arcing due to static electricity, stray currents or lightning can be obtained from API RP 2003, "Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents."

11.3 CATHODIC PROTECTION SURVEYS

11.3.1 Prior to energizing a new cathodic protection system, measurements of the native structure-to-soil potential should be made. Immediately after any cathodic protection system is energized or repaired, a survey should be conducted to determine that it operates properly. An initial survey to verify that it satisfies applicable criteria should be conducted after adequate polarization has occurred. Polarization to a steady state may take several months after the system is energized. This survey should include one or more of the following types of measurements:

- a. Structure-to-soil potential.
- b. Anode current.
- c. Native structure-to-soil potentials.
- d. Structure-to-structure potential.
- e. Piping-to-tank isolation if protected separately.
- f. Structure-to-soil potential on adjacent structures.
- g. Continuity of structures if protected as a single structure.
- h. Rectifier DC volts, DC amps, efficiency, and tap settings.

11.3.2 Annual cathodic protection surveys are recommended to ensure the effectiveness of cathodic protection. The electrical measurements used in the survey may include one or more of the measurements listed above.

11.3.3 Inspection and tests of cathodic protection facilities should be made to ensure their proper operation and maintenance.

11.3.3.1 All sources of impressed current should be checked at intervals not exceeding two months. Evidence of proper function may be current output, normal power consumption, a signal indicating normal operation, or satisfactory electrical state of the protected structure. A satisfactory comparison between the rectifier operation on a bimonthly basis and the rectifier operation during the annual survey implies the protected status of affected structures is similar. This does not take into account possible effects of foreign current sources.

11.3.3.2 All impressed current protective facilities should be inspected annually as part of a preventive maintenance program to minimize in-service failure. Inspections should include a check for electrical shorts, ground connections, meter accuracy, efficiency, and circuit resistance.

11.3.3.3 The effectiveness of isolating devices, continuity bonds, and insulators should be evaluated during the periodic surveys. This can be accomplished by on-site inspection or by evaluating corrosion test data.

11.3.3.4 The tank bottom should be examined for evidence of corrosion whenever access to the bottom is possible. This may be during repairs or modifications, or in conjunction with inspections required by API Standard 653. Examination for bottom-side corrosion may be done by coupon cutouts or

by nondestructive methods such as ultrasonic inspections or electromagnetic flux leakage.

11.3.3.5 Remedial measures should be taken where periodic tests and inspections indicate that protection is no longer adequate according to applicable criteria. These measures may include the following:

- a. Repair, replacement, or adjustment of cathodic protection system components.
- b. Providing supplementary facilities where additional protection is necessary.
- c. Repair, replacement, or adjustment of continuity and interference bonds.
- d. Elimination of accidental metallic contacts.
- e. Repair of defective insulating devices.
- f. Resolution of interference currents.

11.4 CATHODIC PROTECTION RECORDS

11.4.1 The purpose of this section is to describe corrosion control records that will document in a clear, concise, workable manner the data pertinent to the design, installation, operation, maintenance, and effectiveness of corrosion control measures.

11.4.2 In determining of the need for cathodic protection, items listed in 5.2 should be recorded.

11.4.3 In designing cathodic protection systems, the following should be recorded:

- a. Design and location of insulating devices, test leads and other test facilities, and details of other special corrosion control measures taken.
- b. Results of current requirement tests, where made, and procedures used.
- c. Native structure-to-soil potentials before current is applied.

d. Results of soil resistivity tests at the site, where they were made, and procedures used.

e. Name of person conducting surveys.

11.4.4 In installing corrosion control facilities, the following should be recorded:

- a. Impressed current systems.
 1. Location and date placed in service.
 2. Number, type, size, depth, backfill, and spacing of anodes.
 3. Specifications of rectifier or other energy source.
 4. Interference tests and the parties participating in resolution of any interference problems.
- b. Galvanic anode systems.
 1. Location and date placed in service.
 2. Number, type, size, depth, backfill, and spacing of anodes unless part of factory-installed system.

11.4.5 A record of surveys, inspections, and tests described in 11.2.1 and 11.2.3 should be maintained to demonstrate that applicable criteria for cathodic protection have been satisfied.

11.4.6 In maintaining corrosion control facilities, the following information should be recorded:

- a. Repair of rectifiers and other DC power sources.
- b. Repair or replacement of anodes, connections, and cable.
- c. Maintenance, repair, and replacement of coating, isolating devices, test leads, and other test facilities.

11.4.7 Records sufficient to demonstrate the need for corrosion control measures should be retained as long as the facility involved remains in service. Records related to the effectiveness of cathodic protection should be retained for a period of 5 years unless a shorter period is specifically allowed by regulation.

API Related Publications Order Form

Date: _____
(Month, Day, Year)

☐ API Member
(Check if Yes)

Invoice To – ☐ Check here if same as “Ship To”

Company: _____

Name/Dept.: _____

Address: _____

City: _____ State/Province: _____

Zip: _____ Country: _____

Customer Daytime Telephone No.: _____

Fax No.: _____

(Essential for Foreign Orders)

Ship To – (UPS will not deliver to a P.O. Box)

Company: _____

Name/Dept.: _____

Address: _____

City: _____ State/Province: _____

Zip: _____ Country: _____

Customer Daytime Telephone No.: _____

Fax No.: _____

(Essential for Foreign Orders)

☐ Payment Enclosed \$ _____

☐ Payment By Charge Account:

☐ MasterCard ☐ Visa ☐ American Express

Account No.: _____

Name (As It Appears on Card): _____

Expiration Date: _____

Signature: _____

☐ Please Bill Me

P.O. No.: _____

Customer Account No.: _____

State Sales Tax – The American Petroleum Institute is required to collect sales tax on publications mailed to the following states: AL, AR, CT, DC, FL, GA, IL, IN, IA, KS, KY, ME, MD, MA, MI, MN, MO, NE, NI, NY, NC, ND, OH, PA, RI, SC, TN, TX, VT, VA, WV, and WI. Prepayment of orders shipped to these states should include applicable sales tax unless a purchaser is exempt. If exempt, please print your state exemption number and enclose a copy of the current exemption certificate.

Exemption Number: _____ State: _____

Quantity	Order Number	Title	SO*	Unit Price	Total
	C62009	Std 620, Design and Construction of Large, Welded, Low-Pressure Storage Tanks		\$ 145.00	
	C65010	Std 650, Welded Steel Tanks for Oil Storage		\$ 225.00	
	C65202	RP 652, Lining of Aboveground Petroleum Storage Tanks		\$ 60.00	
	C65302	Std 653, Tank Inspection, Repair, Alteration, and Reconstruction		\$ 125.00	
	C57501	RP 575, Inspection of Atmospheric and Low-Pressure Storage Tanks		\$ 75.00	
	C20000	Std 2000, Venting Atmospheric and Low-Pressure Storage Tanks (Nonrefrigerated and Refrigerated)		\$ 75.00	

Shipping and Handling – All orders are shipped via UPS or First Class Mail in the U.S. and Canada. Orders to all other countries will be sent by Airmail. U.S. and Canada, \$5 per order handling fee, plus actual shipping costs. All other countries, for Airmail (standard service) add 25% of order value. All other countries, for UPS Next Day, add an additional 10% of order value.

Rush Shipping Charge – FedEx, \$10 in addition to customer providing FedEx account number: _____. UPS Next Day, \$10 plus the actual shipping costs (1-9 items). UPS

Second Day, add \$10 plus the actual shipping costs (1-9 items).

Rush Bulk Orders – 1-9 items, \$10. Over 9 items, add \$1 each for every additional item. *NOTE: Shipping on foreign orders cannot be rushed without FedEx account number.*

Returns Policy - Only publications received in damaged condition or as a result of shipping or processing errors, if unstamped and otherwise not defaced, may be returned for replacement within 45 days of the initiating invoice date. A copy of the initiating invoice must accompany each return. Material which has neither been damaged in shipment nor shipped in error requires prior authorization and may be subject to a shipping and handling charge. **All returns must be shipped prepaid using third class postage. If returns are due to processing or shipping errors, API will refund the third class postage.**

Subtotal

State Sales Tax (see above)

Rush Shipping Charge (see left)

Shipping and Handling (see left)

Total (in U.S. Dollars)

*To be placed on Standing Order for future editions of this publication, place a check mark in the space provided.

Pricing and availability subject to change without notice.

Mail Orders: American Petroleum Institute, Order Desk, 1220 L Street, N.W., Washington, DC 20005-4070
Fax Orders: (202) 962-4776 Phone Orders: (202) 682-8375

To better serve you, please refer to this code when ordering: **C S 4 2 6 9 1 1 9 7**

The American Petroleum Institute provides additional resources and programs to industry which are based on API Standards. For more information, contact:

- | | |
|--|---------------------------------------|
| • Training/Workshops | Ph: 202-682-8490
Fax: 202-682-8222 |
| • Inspector Certification Programs | Ph: 202-682-8161
Fax: 202-962-4739 |
| • American Petroleum Institute
Quality Registrar | Ph: 202-682-8130
Fax: 202-682-8070 |
| • Monogram Program | Ph: 202-962-4791
Fax: 202-682-8070 |
| • Engine Oil Licensing and
Certification System | Ph: 202-682-8233
Fax: 202-962-4739 |
| • Petroleum Test Laboratory
Accreditation Program | Ph: 202-682-8129
Fax: 202-682-8070 |

In addition, petroleum industry technical, patent, and business information is available online through API EnCompass™. Call 1-888-604-1880 (toll-free) or 212-366-4040, or fax 212-366-4298 to discover more.

To obtain a free copy of the API Publications, Programs, and Services Catalog, call 202-682-8375 or fax your request to 202-962-4776. Or see the online interactive version of the catalog on our web site at www.api.org/cat.



**American
Petroleum
Institute**

**Helping You
Get The Job
Done Right.™**

Additional copies available from API Publications and Distribution: (202) 682-8375

Information about API Publications, Programs and Services is available on the World Wide Web at: <http://www.api.org>



**American
Petroleum
Institute**

1220 L Street, Northwest
Washington, D.C. 20005-4070
202-682-8000

Order No. C65102